

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

10 Brae Burn Way

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Copper	40	1300 MCL
Lead	4.3	15 MCL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.6	1.8 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

108 Russett Lane

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	73	2000 MCL
Iron	13000	26000 RSL
Manganese	43	880 RSL
Nickel	1.2	730 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

110 Concord Road

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	23	2000 MCL
Copper	5.4	1300 MCL
Iron	870	26000 RSL
Lead	1.3	15 MCL
Manganese	21	880 RSL
Vanadium	0.7 J	260 RSL
Zinc	18 J	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Carbon disulfide	0.17 J	1000 RSL
Chloromethane	0.57	1.8 RSL
Methyl T-Butyl Ether (MTBE)	0.19 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

114 Russett Lane

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Aluminum	18 J	37000 RSL
Barium	43	2000 MCL
Iron	48 J	26000 RSL
Nickel	1.3	730 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

117 Russett Lane

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	46	2000 MCL
Copper	6.9	1300 MCL
Iron	5700	26000 RSL
Lead	1.8	15 MCL
Manganese	48	880 RSL
Zinc	11	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Acetone	12 J	22000 RSL
Bromoform	0.43 J	80 *
Methyl T-Butyl Ether (MTBE)	0.11 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

12 Wineberry Lane

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	14	2000 MCL
Copper	4.4	1300 MCL
Iron	470	26000 RSL
Manganese	63	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

15 Forest Run Drive

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	13	2000 MCL
Copper	64	1300 MCL
Lead	4.1	15 MCL
Manganese	2	880 RSL
Nickel	1.1	730 RSL
Zinc	26	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

16 Bethel Drive

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Naphthalene	0.02 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	17	2000 MCL
Copper	3.9	1300 MCL
Iron	1100	26000 RSL
Manganese	78	880 RSL
Zinc	32	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Methyl T-Butyl Ether (MTBE)	0.36 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

16 Forest Run Dr.

Sample Date: 1/22/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Fluorene	0.052 J	1500 RSL
Naphthalene	0.025 J	100 HA
Phenanthrene	0.028 J	1100 RSL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Copper	82	1300 MCL
Iron	120	26000 RSL
Lead	2.5	15 MCL
Manganese	13	880 RSL
Zinc	67	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

2 Brae Burn Way

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Copper	51	1300 MCL
Manganese	1.3	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

2 Moriah Lane

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Naphthalene	0.021 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	44	2000 MCL
Iron	130	26000 RSL
Lead	2.8	15 MCL
Manganese	120	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

20 Bethel Drive

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Pentachlorophenol	0.04 J	1 MCL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	24	2000 MCL
Iron	1400	26000 RSL
Lead	2.7	15 MCL
Manganese	98	880 RSL
Zinc	14	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Methyl T-Butyl Ether (MTBE)	0.2 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

20 Moriah Lane

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	54	2000 MCL
Copper	3.1	1300 MCL
Lead	1.3	15 MCL
Manganese	84	880 RSL
Nickel	1.5	730 RSL
Zinc	24	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

21 Moriah Lane

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.071 J	10 MCL
Barium	120	2000 MCL
Copper	5.3	1300 MCL
Lead	2.8	15 MCL
Manganese	6.1	880 RSL
Selenium	0.24 J	50 MCL
Vanadium	1.7 J	260 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Tetrachloroethene	0.26 J	5 MCL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

22 Moriah Lane

Sample Date: 1/20/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Naphthalene	0.023 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.082 J	10 MCL
Barium	29	2000 MCL
Copper	20	1300 MCL
Iron	230	26000 RSL
Lead	4.9	15 MCL
Manganese	1.2	880 RSL
Vanadium	1.9 J	260 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.23 J	1.8 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

23 Moriah Lane

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.13 J	10 MCL
Barium	15	2000 MCL
Copper	3	1300 MCL
Iron	210	26000 RSL
Manganese	65	880 RSL
Vanadium	1.4 J	260 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

24 Pinner's Cove Road

Sample Date: 1/22/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Acenaphthene	0.031 J	2200 RSL
Pentachlorophenol	0.057 J	1 MCL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	15	2000 MCL
Copper	12	1300 MCL
Manganese	1.3	880 RSL
Zinc	21	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

24 Walsh Trace Drive

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Fluorene	0.021 J	1500 RSL
Naphthalene	0.016 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	16	2000 MCL
Copper	6.8	1300 MCL
Manganese	2.2	880 RSL
Zinc	46	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloroform	3.3	80 *

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

25 Moriah Lane

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Fluorene	0.024 J	1500 RSL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	27	2000 MCL
Manganese	48	880 RSL
Nickel	1.2	730 RSL
Zinc	27	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

26 Ratman Drive

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Copper	4.7	1300 MCL
Manganese	2.9	880 RSL
Zinc	230	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Bromodichloromethane	2.9	80 *
Bromoform	0.53	80 *
Chloroform	17	80 *
Dibromochloromethane	0.29 J	80 *

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

260 Williams Road

Sample Date: 1/20/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Benzo(a)pyrene	0.036 J	0.2 MCL
Naphthalene	0.025 J	100 HA
Pyrene	0.02 J	1100 RSL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.096 J	10 MCL
Copper	50	1300 MCL
Iron	200	26000 RSL
Lead	2.6	15 MCL
Manganese	9.2	880 RSL
Vanadium	0.8 J	260 RSL
Zinc	140 J	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.51	1.8 RSL

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

27 Moriah Lane

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.1 J	10 MCL
Barium	20	2000 MCL
Iron	500	26000 RSL
Manganese	100	880 RSL
Vanadium	1.3 J	260 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.21 J	1.8 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

274 Williams Road

Sample Date: 1/20/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Benzo(a)pyrene	0.016 J	0.2 MCL

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.078 J	10 MCL
Copper	69	1300 MCL
Iron	140	26000 RSL
Vanadium	0.6 J	260 RSL
Zinc	32 J	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.49 J	1.8 RSL
Methyl T-Butyl Ether (MTBE)	0.17 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

28 Moriah Lane

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.13 J	10 MCL
Barium	19	2000 MCL
Copper	3.4	1300 MCL
Iron	830	26000 RSL
Manganese	100	880 RSL
Nickel	1.8 J	730 RSL
Vanadium	1.7 J	260 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Carbon disulfide	0.47 J	1000 RSL
Chloromethane	0.15 J	1.8 RSL
Methyl T-Butyl Ether (MTBE)	0.38 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

296 Williams Road

Sample Date: 1/20/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Arsenic	0.14 J	10 MCL
Copper	11	1300 MCL
Lead	3.7	15 MCL
Selenium	2.4 J	50 MCL
Vanadium	1.4 J	260 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

3184 Sweeten Creek Road

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Copper	25	1300 MCL
Iron	1100	26000 RSL
Lead	1.4	15 MCL
Manganese	50	880 RSL
Zinc	24	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.7	1.8 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

32 Concord Road

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
2-Methylnaphthalene	0.095 J	150 RSL
Naphthalene	0.078 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Aluminum	15 J	37000 RSL
Barium	22	2000 MCL
Copper	31	1300 MCL
Iron	160	26000 RSL
Lead	2.5	15 MCL
Manganese	1.7	880 RSL
Zinc	23	11000 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

33 Chapel Hill Church Road

Sample Date: 1/19/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Iron	2800	26000 RSL
Manganese	100	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

42 Chapel Hill Church Road

Sample Date: 1/19/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Aluminum	1000	37000 RSL
Barium	21	2000 MCL
Chromium	7.2	100 MCL
Copper	4.3	1300 MCL
Iron	2300	26000 RSL
Lead	22	15 MCL
Manganese	68	880 RSL
Nickel	7.5	730 RSL
Zinc	100	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Carbon Tetrachloride	0.062 J	5 MCL
Chloroform	1.5	80 *
Chloromethane	0.28 J	1.8 RSL
Toluene	0.65	1000 MCL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

42 Concord Road

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	20	2000 MCL
Copper	70	1300 MCL
Iron	180	26000 RSL
Lead	16	15 MCL
Manganese	1.6	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

50 Concord Road

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Iron	1200	26000 RSL
Manganese	110	880 RSL
Vanadium	1	260 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

501 Mills Gap Road

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Barium	18	2000 MCL
Copper	50	1300 MCL
Iron	9400	26000 RSL
Lead	3	15 MCL
Manganese	260	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

56 Chapel Hill Church Road

Sample Date: 1/19/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Iron	3300	26000 RSL
Manganese	110	880 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.22 J	1.8 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

6 Forest Run Drive

Sample Date: 1/22/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Aluminum	450	37000 RSL
Barium	20	2000 MCL
Copper	50	1300 MCL
Iron	1200	26000 RSL
Lead	29	15 MCL
Manganese	80	880 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

613 School Road

Sample Date: 1/21/2009

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Iron	580	26000 RSL
Manganese	150	880 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Dichlorodifluoromethane (Freon)	0.12 J	390 RSL
Methyl T-Butyl Ether (MTBE)	0.13 J	12 RSL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

619 School Road

Sample Date: 1/21/2009

Semivolatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Naphthalene	0.017 J	100 HA

Total Metals

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Aluminum	53 J	37000 RSL
Barium	28	2000 MCL
Copper	10	1300 MCL
Iron	170	26000 RSL
Manganese	120	880 RSL
Nickel	1.3	730 RSL
Zinc	11	11000 RSL

Volatile organic compounds

Analyte	Result (ug/L)	Health Screening Level (ug/L)
Chloromethane	0.62	1.8 RSL
trans-1,2-Dichloroethene	0.13 J	100 MCL

Notes:

HA = Health Advisory

J = The identification of the analyte is acceptable; the reported value is an estimate.

MCL = Federal Drinking Water Maximum Contaminant Limit

RSL = http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/index.htm

ug/L = Micrograms per liter

* = Trihalomethanes; the sum total detected concentration from bromodichloromethane, bromoform, chloroform, and dibromochloromethane should be compared to the MCL (80 ug/L)